

October 12, 1953

Board of Directors  
Odd Fellows Sierra Recreation Park

Dear Board Members:

Bob Hodgson, Chairman, Roy Akers, Engineer, Noah Van Hook, W. F. Greeno, E. R. Carlin, members of the Construction Committee wish to make the following report on Water #2.

The pipe layout was placed on a subdivision map one week after we were appointed to the job of producing a plan.

Previous to our acceptance of the water job, transite pipe had been discussed and accepted by the general committee but no real plan had been presented.

Our committee discussed the problem of installation and the cost of transite. We found that installation and cost would be beyond the means of the association. We considered plastic pipe and asked a representative to present the facts and figures of a proposed plan to the General Committee and other interested members.

Our committee recommended to the General Committee on October 11, 1953 and recommend now to the Board of Directors the following:

We suggest that the source of water supply be the overflow from the E. O. Sylvester spring as a temporary supply until further needs are required. Then other sources will be developed. A redwood tank with a 55 lb. pressure system with the main line being 2" plastic pipe #110 with lead offs of 1½" pipe and 1". This will place water within 100 feet of each surveyed lot. Elevations of the subdivision were taken and a map made of the suggested pipe lines. This was presented to Mr. M. Welch, Sales Representative and Mr. Cliff Fuller, engineer for Plastic Pipe. The engineer reports that the plan is satisfactory and made a few suggestions for future developments.

This plan includes 25 fire hydrants in convenient places and outlets in the street for the lots.

The Plastic Pipe Company will send a man to help install and instruct us in the proper installation of the pipe. Their engineer is available on any problems we may have in installing our water system at no cost.

The committee feels this plan will probably not exceed \$8500 for materials.

Bob Hodgson, Chairman  
Construction Committee

Roy Akers, Engineer  
Noah Van Hook  
W. F. Greeno  
E. R. Carlin