



PORTER / CAL-WESTERN

Lic. #247908

19393 Cordelia Avenue
Sonora, California 95370
209/533-0567

FAX MESSAGE

OCTOBER 5 ,1998

TUOLUMNE COUNTY HEALTH DEPT.

TRACEY FITZGERALD

MESSAGE:

HI TRACEY, PLEASE FIND ENCLOSED THE FINAL CERTIFICATE ON THE
ODDFELLOWS PARK 220, 000 GALLON TANK INTERIOR COATING.....

IT IS FULLY COATED WITH THE CIM1061 POTABLE WATER MEMBRANE
THAT YOU HAVE ON FILE.....

IT WAS DISINFECTED ON 10/5/98 AND IS PRESENTLY IS BEING TESTED FOR
BAC-T WITH AQUA LAB....THE LAB WILL CONTACT YOU WITH THE
RESULTS.

*Item by
owals*
THIS TANK HAD 6 SCREENED VENTS ADDED TO THE TOP AND A SWING
CHECK TO THE OVERFLOW WITH A NEW SCREEN....WE ARE UPDATING
ALL OVERFLOWS AS PART OF THE TANK PACKAGE NOW.....

IT IS A VERY SANITARY UNIT AND SHOULD GIVE MANY YEARS OF FINE
SERVICE.....

ADDED A SMALL SLUDGE TAP 3" OFF THE FLOOR ALSO FOR FUTURE
MAINTENANCE

ADDED TOP LOAD STUB FOR FUTURE TIE IN..... ALL SANITARY CAPPED...

THANK YOU

ROSS

