

# Certificate

I Ross Porter (print) do hereby state as a duly licensed applicator that I personally oversaw the following project and that it was performed as per manufacturers specifications for safety and sanitation.

(see product data on file with TCHD)

The work was performed between the dates of: 9/20/98  
and 10/5/98.

This date is: 10/5/98.

Project name: ODDFELLOWS GIERA PARK Number 98-007

Contractor: Porter / Cal-Western Inc. #247908 19393 Cordelia Ave.

Sonora, CA. 95370 (209-533-0567) EPA 000099391 — TCHD (file copy) st.ca. class II dwr

Coating applied on interior was: CIM # 1061 Potable Water Epoxy

Coating applied on exterior: NONE (ROOF CARBOLINE 90)

(MSDS -PDPD) on file TCHD-97

The coating was under cure for: 10 DAYS

Ventilation method: FORCE AIR 6000 CFM Ambient

Hatch and vent data: ADD 460 sq. W. SCREEN VENT 0.16 W.E.S.H.

Sterilization data: ISOPP HCL fog saturation 120 minutes 95°F

Bacteria test data: BY OWNER

Other: ADD REAR HATCH / SOME ROOF SUPPORT /

Signed: [Signature] (Print name) Ross Porter

Title: CEO

Date: 10/5/98

File copy with TCHD and owner upon completion of project

Contractor has filed copy T.C.H.D.  
10/5/98