

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Sierra Park Water Co. Has Levels of Manganese Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results received on 10/02/2017 showed Manganese levels of 198 ug/L for Well #5 and 310 ug/L for Well #6. This is above the standard, or maximum contaminant level (MCL), of 50 ug/L.

What should I do?

- You do not need to use an alternative water supply (e.g., bottled water).
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

At this time the Sierra Park Water Company has been instructed by the CPUC to put on hold any expenses related to the Manganese Removal Project until further instructions are given. There is currently an Engineering Study underway to review our options.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities):
Must notify tenants.
 - For more information, please contact Kirk Knudsen at 209 586-3098 or P.O. Box 424, Mi-Wuk Village, Ca. 95346

This notice is being sent to you by Sierra Park Water Company.

State Water System ID#: 5510016. Date distributed:



PRECISION ENVIRO-TECH

Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

EDT

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

4542.P

Date of Report: 18/08/27

Sample ID No.8082411-01

Laboratory

Signature Lab

Name: PRECISION ENVIRO-TECH ANALYTICAL LAB

Director: Jonathan Hao V. Le

Name of Sampler: Dave Roy

Employed By: Aqualab

Date/Time Sample

Date/Time Sample

Date Analyses

Collected:18/08/23/0700

Received @ Lab:18/08/24/1204

Completed:18/08/24

System

System

Name:SIERRA PARK WATER COMPANY, INC.

Number: 5510016

Name or Number of Sample Source:WELL 05

* User ID: AGE

Station Number: 5510016-006 *

* Date/Time of Sample: |18|08|23|0700|

Laboratory Code: 2213 *

* YY MM DD TTTT

YY MM DD *

* Date Analysis completed: |18|08|24| *

* Submitted by: _____ Phone #: _____ *

PAGE 1 OF 1

INORGANIC CHEMICALS

MCL	REPORTING	CHEMICAL	ENTRY	ANALYSES	DLR
	UNITS		#	RESULTS	
50	ug/L+	Manganese (Mn) (ug/L)	01055	275	20.0

+ Indicates Secondary Drinking Water Standards



PRECISION ENVIRO-TECH Analytical Laboratory

3935 N. Coronado Ave, Stockton CA. 95204 Phone: (209) 477-8105

EDT

GENERAL MINERAL & PHYSICAL & INORGANIC ANALYSIS (9/99)

4542.Q

Date of Report: 18/08/27 Sample ID No. 8082411-02
 Laboratory Signature Lab
 Name: PRECISION ENVIRO-TECH ANALYTICAL LAB Director: Jonathan Hao V. Le
 Name of Sampler: Dave Roy Employed By: AquaLab
 Date/Time Sample Date/Time Sample Date Analyses
 Collected: 18/08/23/0700 Received @ Lab: 18/08/24/1204 Completed: 18/08/24

=====
 System System
 Name: SIERRA PARK WATER COMPANY, INC. Number: 5510016
 Name or Number of Sample Source: WELL 06

 * User ID: AGE Station Number: 5510016-007 *
 * Date/Time of Sample: |18|08|23|0700| Laboratory Code: 2213 *
 * YY MM DD TTTT YY MM DD *
 * Date Analysis completed: |18|08|24| *
 * Submitted by: _____ Phone #: _____ *

PAGE 1 OF 1 INORGANIC CHEMICALS

MCL	REPORTING UNITS	CHEMICAL	ENTRY #	ANALYSES RESULTS	DLR
300	ug/L+	Iron (Fe) (ug/L)	01045	312	100.0
50	ug/L+	Manganese (Mn) (ug/L)	01055	282	20.0

+ Indicates Secondary Drinking Water Standards