

## **IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

Este informe contiene información muy importante sobre su agua potable.  
Tradúzcalo o hable con alguien que lo entienda bien.

### **Sierra Park Water Co. Has Levels of Manganese Above the Drinking Water Standard**

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results received on 02/22/2018 showed Manganese levels of 193 ug/L for Well #5 and 298 ug/L for Well #6. This is above the standard, or maximum contaminant level (MCL), of 50 ug/L. Well # 6 also recorded (ug/L) levels off 1650 for Iron. MCL is 300 ug/L+.

#### **What should I do?**

- **You do not need to use an alternative water supply (e.g., bottled water).**
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

#### **What happened? What is being done?**

At this time the Sierra Park Water Company has been instructed by the CPUC to put on hold any expenses related to the Manganese Removal Project until further instructions are given. There is currently an Engineering Study underway to review our options.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.*

#### **Secondary Notification Requirements**

- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities):** Must notify tenants.
- For more information, please contact Kirk Knudsen at 209 586-3098 or P.O. Box 424, Mi-Wuk Village, Ca. 95346

This notice is being sent to you by Sierra Park Water Company.

State Water System ID#: 5510016. Date distributed:

