

DOLFELLOW SIERRA PARK		SCURCE	TOBOGAN		MONTH	YEAR	
			WELL #3		AUG	1988	
	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
2	04183300	PUMPED	OUT AND	STARTED	BLENDING	INTO SYSTEM	8/2/88 JH
3	04188800		WORKED	ON	METER	- NEEDS	REPLACED JH
4	04189000						
5	SAME	- METER	STUCK	-	WORKED	ON	METER AND REINSTALLED, JH
6	04191200						
9	SAME		METER	QUIT	WORKING	COMPLETELY	JH
10	"						
11	"						
12	"						
13	"						
16	"						
17	"	REPLACED	OLD	METER	100	NEW	3/4" METER JH
18	0008500						
19	0019410						
20	0030530						
23	0060720						
24	0079170						
25	0082250						
26	0099330						
27	0009420						
30	0139000						
31	0154290						

153680

DEWELL - SIERRA PARK

TO BODGAN SOURCE WELL # 3 MONTH SEPT.

YEAR 1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	0165690						
2	0177190						
3	0189240						
4	0200220						
5	211840						
6	223460						
7	235090						
8	246700						
9	256710						
10	268460						
11	280160						
12	291960						
13	302670						
14	314350						
15	325870						
16	337400						
17	349360						
18	361400						
19	373190						
20	383680						
21	395060						
22	406780						
23	419060						
24	430100						
25	441720						
26	453630						
27	466400						
28	488450						
29	488580						
30	501070						
31	513120						

347730 gallons



TOROGAN

DDFELLOW SIERRA PARK

SOURCE

WELL # 3

MONTH

DEC

YEAR

1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	1256530						
2	1270050						
3	1281010						
5	1306090						
6	1318950						
7	1330020						
8	1342500						
9	1354790						
10	1367750						
12	1393290						
13	1404570						
14	1416230						
15	1428480						
16	1440790						
17	1440790						12-20-88 PUMP SHUT DOWN THRU SNOW STORMS
		184260					