

OFFELLOW SIERRA PARK

SOURCE

KERN CREEK
WELL #5

MONTH JAN

YEAR 1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	27977100					14-1200	
2	28028100					12-1100	
3	28078700					11-1500	
4	28129600					12-1500	
5	28180600					12-1200	
6	28231600					13-1400	
7	28423700					12-0900	
-	28438500					14 1/2 - 0900	
9	28453300					16-0900	
10	28513400					18-0930	
11	28573700					20 1/2 - 0930	
12	28633800					22 1/2 - 0900	
13						23 1/2 - 0930	PUMP OFF AT 0930
14						22 - 0930	
15						20 1/2 - 0900	PUMP ON AT 0930
16	28705200					20 1/2 - 0930	PUMP OFF AT 0930
17	28772600					21-0930	
18	28843200					22-0930	
19	28923600					22 1/2 - 0930	
20	28991800					23 1/2 - 0900	PUMP OFF AT 0930
21						22 - 0930	
22						20 1/2 - 0830	
23						19 - 0830	PUMP ON AT 1430
24	29141800					22 - 0830	PUMP OFF AT 1630
26						21	
27						19 1/2	
28						18	
29						17-0900	PUMP ON AT 0930
30	29208900					18 1/2 - 0830	
		1231800					

DFELLOW SIERRA PARK

SCURCE

KERN CREEK
WELL #5

MONTH FEB.

YEAR 1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
2	29414500					22	- 10:00
3	29489000					23 1/2	- 10:00 - PUMP OFF AT 10:30
4							
5						20	- 09:30 - PUMP ON AT 10:00
6	29548600					21	- 09:00
9	29786900					23 1/2	- 08:30 - PUMP OFF AT 09:00
11						19	- 09:00 - PUMP ON AT 09:30
12	29863000					21	- 08:00
13	29945900					21 1/2	- 08:30
15	30109400					20	- 08:30
16	30201100					21 1/2	- 08:30
17	30282200	MORNING READING				23	- 08:30
17	30303800	(AFTER NOON READING)				23 1/2	- PUMP OFF AT 16:00
18						22	- 09:00
19						21	- PUMP ON AT 09:00
20	30386800	MORNING READING				22 1/2	- 08:30
20	30415700	AFTER NOON READING				23 1/2	- PUMP OFF AT 17:00
23						19	- 08:00 - PUMP ON AT 08:30
24	30497900					21 1/2	- 08:30
25	30585800					22 1/2	- 08:30
26	30662100					23 1/2	- 08:00 - PUMP OFF AT 08:30
27						22	- 08:00
28							
29							
	2 total	1247600					

DDFELLOW SIERRA PARK

SOURCE

KERN CREEK
WELL #5

4TH MARCH

YEAR 1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1						18 1/2	0830 PUMP ON AT 0900
2	30743800					20	0830 - PUMP ON AT 0900
3	30817400					21 1/2	0830
4	30888100					23 1/2	0830 - PUMP OFF AT 0845
5						22	0830
8						18	0830 PUMP ON AT 0900
9	PUMP TURNED OFF AT 0930 TO INSTALL NEW PUMP					20	0830
10	30962300					19	0800 - PUMP ON AT 1000
11	31323300 -					23 1/2	0830 - PUMP OFF AT 0900
12	PUMP OFF AT 1630 - TANK LEVEL - 23					22	0830 - PUMP ON AT 0900
15	31446800					19 1/2	0830 - PUMP ON AT 1000
16	31816900					23 1/2	0800 - PUMP OFF AT 0830
17						22 1/2	0800
18						21	0800
19						19 1/2	0800 - PUMP ON AT 0830
20	32281600					23 1/2	0900 - PUMP OFF AT 0930
22						21	0800 - PUMP ON AT 0830
23	32681500					23 1/2	0800 - PUMP OFF AT 0830
24						22	0500
25						21	0500 - PUMP ON AT 1800
26	32873300					22 1/2	0800
26	32976000					23 1/2	0800 - PUMP OFF AT 0800
29						19	0500 - PUMP ON AT 0830
30	33225800					23	0800 - PUMP OFF AT 0830
31						21 1/2	0800
		2482,000					

KERN CROWELL

ODFELLOW SIERRA PARK

SCURCE

5

MONTH

~~JUNE~~ JUNE

YEAR 1989

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	37655300					22-0830	
2	37688300					22-0800	
3	37732100					22-0830	
4	37741100					21-0800	PUMP OFF-1600
7							
8							
9							-PUMP ON-1600
10	37927700					19 1/2-0800	
11	38116700					22 1/2-0800	PUMP OFF 0830
14						18 1/2-0800	PUMP ON 0830
15	38459200					21 1/2-0800	" OFF-0830
16						21 1/2-0800	
17						20 1/2-0800	PUMP ON AT 11:30
18	38755500					22 1/2-0800	
21	39112100					22 1/2-0800	PUMP SWITCHED BACK TO AUTOMATIC-CONTROL
22	39239800					23-0800	
23	39303500					23-0800	
24	39383400					23-	"
25	39499500					23-	"
28	39835600					23-	"
29	39934400					23-	"
30	40003200					23-	"
31	40003200						
		2349900					

KERN CREEK

DE FELLOW SIERRA PARK

SOURCE

WELL #5

MONTH

SEPT,

YEAR

1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	46385600					23	- 0800
2	46495600					23	- 0800
3	46605600					23	- 0800
4	46915300					22 1/2	- 0830
5	47014600					23	- 0830
6	47149000					22	- 0830
7	47411100					22	- 0830
8	47411100					22	- 0830
9	47431300					22 1/2	- 0830
10	47483100					23	- 0830
11	47514000					22	- 0830
12	47530000					22	- 0830
13	47585800					22	- 0830
14	47585800					22	- 0900
15	47711800					22	- 0830
16	47711800					23	- 0830
17	47784200					22 1/2	- 0800
18	47891600					22	- 0800
19	47956800					22	- 0800
20	47956800					22	- 0830
21	47956800					22	- 0830
22	47999800					22	- 0830
23	47999800					22	- 0830
24	48036900					23	- 0830
25	48096500					22 1/2	- 0800
26	48181800					22	- 0800
27	48208300					23	- 0800
28	48208300					23	- 0830
29	48250400					22	- 0830
30	48250400					23	- 0830
31	48303300					23	- 0830

1,917,700 gallons

(2,414,180) Total for month

KERN CO.

DDFELLOW SIERRA PARK

SOURCE

WELL #5

MONTH OCT.

YEAR 1988

	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
4	48421400					23	-0800
5	48421400					23	-0800
6	48421400					23	-0800
7	48460000					23	-0800
8	48460000					22 1/2	-0800
11	48636500					23	-0800
12	48636500					23	-0800
13	48636500					23 1/2	-0830
14	48636500					23 1/2	-0800
15	48636500					23	-0830
16	48684700					23	-0800
17	48727000					23	-0800
18	48727000					23	-0830
19	48727000					23	-0830
20	48727000					23	-0800
21	48727000					23	-0830
22	48765900					23	-0800
24	48765900					23	-0900
25	48765900					23	-0800
26	48765900					23	-0800
27	48765900					23	-0830
28	48765900					23	-0830
29	48800800					23	-0830
30	48853600					23	-1030
31	48902400					31	-1030
		491000					
		882150					

2.764

882150

DUFELLOW SIERRA PARK		SOURCE <u>KERN CR. WELL #5</u>		MONTH <u>DEC.</u>		YEAR <u>1988</u>	
	METER READING	GALLONS	CHLORINE	PH	GPM	TANK LEVEL	REMARKS
1	50035000					23	0830
2	50059000					23	0830
3	50059000					23	0900
5	50059000					23	0830
6	50059000					22 1/2	0830
7	50059000					23	1000
8	50059000					23	0830
9	50059000					23	0830
10	50059000					23	0900
12	50059000					22 1/2	0830
13	50059000					23	0930
14	50059000					23	0830
15	50059000					23 1/2	0830
16	50059000					23 1/2	0830
17	50111100						
20		WELL SET ON MANUAL CONTROL					
21							
22		NOT READ AGAIN UNTIL JAN. 11 1989					
23		JAN. 11, 1989 READING = 55277200					
24		(WELL RESET TO AUTOMATIC CONTROL. TANK GAUGE THAWED OUT AND FOUND TO BE FULL 1-11-89)					
27							
28							
29							
30							
31		76100					<i>JH</i>
		Total 293440					